

RK300-13 VOC Concentration Sensor

Hunan Rika Electronic Tech Co.,Ltd
Add: 401, 1st Unit, 10th Bd, International Enterprise Center, No.268 Xinxing Rd, Yuhua Dist,
Changsha, 410116 Hunan, China.
T:+86-731-85132979
E:info@rikasensor.com
W:www.rikasensor.com

RK300-13 volatile organic compound gas sensor is a gas detection product developed and produced by our company; RK300-13 adopts MEMS principle and can be used for VOC gas detection in various environments. The sensor has the advantages of stable signal, high precision and fast response speed.

APPLICATION

- Medical equipment
- HVAC and air conditioning
- Industrial control
- Environmental monitoring

SPECIFICATIONS

Item	Specification
Measuring range	0-10ppm
Supply	Mark on the label
Resolution	0.001ppm
Accuracy	±3%rdg@25℃
Response time	≤2s
Output	RS485
Power consumption	≤0.2W
Operating temperature	-20~+50℃
Relative humidity	0-95%RH（No condensation）
Shell Material	ABS

1 MENSION



ELECTRICAL CONNECTIONS

Connector (cable)	RS485
Red	V+
Black	V-
Yellow	485A
Green	485B

Note: This product has been tested and complies with European CE requirements for EMC directive.

PARAMETER SELECTION TABLE

Remark	Series	Type	Indoor /Outdoor	Range	Output	Supply	Cable Length	
RK								
	300							
		13						
			A					Indoor
			B					Outdoor
				A				0-10ppm
				X				Other
					A			4-20mA
					B			RS485 (modbus-RTU)
					X			Other
						A		12-24VDC
						X		Other
							2000	Units:mm (typ)
							3000	Units:mm
							...	Units:mm

Example:RK300-13BAAA2000 Outdoor,Range:0-10ppm, output:4-20mA,Supply:12-24VDC,Cable Length:2m.

Communication Protocol (MODBUS)

Transmission mode: MODBUS-RTU,Baud rate: 9600bps,Data bits:8,Stop bit:1,Check bit:no

Slave address:the factory default is 01H (set according to the need,00H to EFH)

- The 03H Function Code Example: Read The VOC concentration

Host Scan Order(Slave addr:0x01):

01 03 00 00 00 01 840A

Slave Response:

01 03 02 00 9B F9EF

VOC :(009B)H=(155)D =155ppm

- The 06H Function Code Example: Modify the slave address(fixed command,ensure that no other devices on the bus)

Host Scan Order (Changed 01H to 02H):

01 06 00 30 00 02 0804

Slave Response:

01 06 00 30 00 02 0804

5

7

Note:

1. All underlined is fixed bit;
2. The last two bytes is CRC check command



Complies with applicable CE directives.
Manual subject to change without notice. Version 1.0
Copyright © 2015 Hunan Rika Electronic Tech Co.,Ltd

8