

RK300-07 NH₃ Concentration Sensor

Hunan Rika Electronic Tech Co.,Ltd

Add: 401, 1st Unit, 10th Bd, International Enterprise Center, No.268 Xinxing Rd, Yuhua Dist, Changsha, 410116 Hunan, China.

T:+86-731-85132979

E:info@rikasensor.com

W:www.rikasensor.com

RK300-07 Ammonia gas sensor adopts professional test ammonia concentration sensor probe as the core detection device; it has the characteristics of wide measurement range, high accuracy, good linearity, good versatility, convenient use, easy installation, long transmission distance, and moderate price.

APPLICATION

- Medical equipment
- HVAC and air conditioning
- Industrial control
- Environmental monitoring

SPECIFICATIONS

Item	Specification
Measuring range	0-100ppm
Principle	Electrochemistry
Supply	Mark on the label
Resolution	0.01ppm
Accuracy	±3%@25℃
Response time	≤15s
Output	RS485
Power consumption	≤0.2W
Operating temperature	-20-+50℃
Relative humidity	0-95%RH（No condensation）
Shell Material	ABS

DIMENSION



ELECTRICAL CONNECTIONS

Connector（cable）	RS485	Voltage
Red	V+	V+
Black	V-	V-
Yellow	RS485A	Signal+
Green	RS485B	

Note: This product has been tested and complies with European CE requirements for EMC directive.

PARAMETER SELECTION TABLE

Remark	Series	Type	Indoor /Outdoor	Range	Output	Supply	Cable Length	
RK								
	300							
		07						
			A					Indoor
			B					Outdoor
				A				0-100ppm
				X				Other
					A			4-20mA
					B			RS485（modbus-RTU）
					X			Other
						A		12-24VDC
						X		Other
							2000	Units:mm（typ）
							3000	Units:mm
							...	Units:mm

Example: RK300-07BAAA2000 Outdoor,Range:0-100ppm, output:4-20mA,Supply:12-24VDC,Cable Length:2m.

Communication Protocol（MODBUS）

Transmission mode: MODBUS-RTU,Baud rate: 9600bps,Data bits:8,Stop bit:1,Check bit:no

Slave address:the factory default is 01H (set according to the need,00H to FFH)

- The 03H Function Code Example: Read The NH₃ concentration

Host Scan Order(Slave addr:0x01):

01 03 00 00 00 01 840A

Slave Response:

01 03 02 00 10 7835

NH₃ :(0010)H=(16)D,16=16ppm

- The 06H Function Code Example: Modify the slave address(fixed command,ensure that no other devices on the bus)

Host Scan Order (Changed 01H to 02H):


01 06 00 30 00 02 0804

Slave Response:

01 06 00 30 00 02 0804

Note:

1. All underlined is fixed bit;
2. The last two bytes is CRC check command

 Complies with applicable CE directives.
Manual subject to change without notice. Version 1.0
Copyright © 2015 Hunan Rika Electronic Tech Co.,Ltd